



# South Norwalk Electric and Water

One State Street  
Norwalk, CT 06854  
(203) 866-4446

## 2019 Water Quality Report

SNEW serves South Norwalk, Rowayton, and portions of Silvermine, East Norwalk, West Norwalk and Wilton

This “2019 Water Quality Report”, or Consumer Confidence Report, is issued annually to educate you, our valuable customer regarding your drinking water. It will provide you with information on the source of your drinking water, how it is treated and monitored, what it contains and how it compares to standards set by regulatory agencies. South Norwalk Electric and Water (SNEW) PWS ID# CT1030021 performs over 30,000 analyses annually on about 3,500 samples while looking for more than 90 possible contaminants. Many of the analyses are conducted by SNEW’s state certified public health laboratory.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

### SOURCES OF YOUR DRINKING WATER

Your drinking water comes from four reservoirs located in the Towns of Wilton and New Canaan, CT. They include City Lake, Rock Lake and Popes Pond Reservoirs in Wilton and the New Canaan Reservoir in New Canaan. The watershed area totals 6,300 acres in these towns, with SNEW owning about 19%. We have an excellent watershed protection program which includes property inspections and water quality sampling to safeguard our sources from pollution assuring that we maintain the highest quality water in these reservoirs.

A source water assessment of our supply system was completed by the Department of Public Health Drinking Water Section. The assessment found that our public drinking water source has a low susceptibility to potential sources of contamination. The assessment report can be found on the CT DPH website: <http://www.dir.ct.gov/dph/Water/SWAP/Community/CT1030021.pdf>

Our customers can play an important role in helping to preserve this most important natural resource in two ways, **source protection and conservation**. Inspecting septic systems on a regular basis and promptly repairing any problems, using fertilizers sparingly and carefully following manufacturer’s directions, replacing leaky oil tanks, disposing of hazardous household materials properly and reporting any incidences of pollution are ways customers can help to protect the source. Practicing conservation will help to maintain an adequate supply of clean drinking water. Reporting any outside leaks, promptly fixing toilet leaks and leaking fixtures, turning off the faucet when shaving and brushing teeth, running dishwashers and washing machines with full loads, watering lawns and plants during early morning or evening, and keeping sprinklers on the lawn, not the pavement are ways you can conserve water and save money on your water bill too.

### WATER TREATMENT PROCESS

Water from SNEW reservoirs undergoes rigorous treatment at our Filtration Plant in Wilton. The treatment process includes raw water coarse and fine screens, alum coagulation with rapid mixing and flocculation, membrane filtration by an immersed membrane ultrafiltration process and granular activated carbon filters for taste and odor control. In the final step a disinfectant is added to protect against microbial contaminants and fluoride is added to aid in dental health. The treatment process also includes an automated control and data acquisition system as well as chemical delivery, storage and pumping systems. The treatment process removes contaminants and helps SNEW maintain compliance with all current State and Federal EPA regulations. We serve approximately 42,000 people and treat an average of 5.9 million gallons per day distributed through a network of 135 miles of pipeline.

### WATER QUALITY MONITORING

To insure the purity of the water supplied to you, we undertake an extensive water sample collection and testing program. Our source water monitoring serves as an early warning system of potential pollution of our reservoirs. The water then goes through our filtration facility and is tested continuously at various stages to monitor the performance of the treatment processes. Finally, we collect samples from the distribution system, as well as at taps of individual customers, to ensure the quality of the water you drink.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by contacting the EPA’s Safe Drinking Water Hotline at 1-800-426-4791 or [hotline-sdwa@epa.gov](mailto:hotline-sdwa@epa.gov).

### CONTAMINANTS THAT MAY BE PRESENT IN SOURCE WATER INCLUDE:

**Microbial contaminants**, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining and farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm runoff, and septic systems.

**Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### IMPORTANT INFORMATION

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Some people who drink water containing Trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

**Lead and Copper Statement:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead and copper in drinking water are primarily from materials and components associated with service lines and home plumbing. SNEW is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead and copper exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

In 2019, SNEW tested for over 90 regulated substances. Listed below are the 14 substances that were detected. All are below allowable levels. The data presented are from the most recent testing done in accordance with the regulations and all were sampled in the year 2019 unless otherwise noted.

Water Quality Table				
Substance	MCLG	MCL	Highest Level Detected (range)	Major sources in drinking water
<b>Regulated at the Treatment Plant</b>				
Barium	2 ppm	2 ppm	0.037 ppm	Erosion of natural deposits; Discharge of drilling wastes; Discharge from metal refineries
Chloride	N/A	250 ppm	39.0 ppm (33.6 – 39.0)	Natural deposits; Runoff from road salting
Chlorine	MRDLG = 4 ppm	MRDL = 4 ppm	1.40 ppm (0.62 – 1.40)	Water additive used to control microbes
Fluoride	4 ppm	4 ppm	0.68 ppm (0.59 - 0.68)	Erosion of natural deposits; Water additive which promotes strong teeth
Nitrate	10 ppm	10 ppm	0.29 ppm (0.01 - 0.29)	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium	N/A	28 ppm (Notification Level *)	24.0 ppm (18.0 - 24.0)	Natural deposits; Runoff from road salting; Treatment process by-product
Total Organic Carbon (TOC)	N/A	TT = TOC removal ratio ≥ 1.0 based on 4-quarter running annual average	1.00 lowest 4-quarter running annual average (1.00– 1.28)	Naturally present in the environment
Turbidity	N/A	TT = at least 95% of monthly samples < 0.3 NTU	100.0% < 0.3 NTU	Soil runoff, sediment particles
		TT = 1 NTU	0.11 NTU (0.04 - 0.11)	
<b>Regulated at the Customer's Tap</b>				
Copper (2019)	1.3 ppm	AL = 1.3 ppm 100% of samples lower than AL	0 samples of 36 higher than 1.3 ppm (90 <sup>th</sup> percentile = 0.16 ppm)	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (2019)	0 ppb	AL = 15 ppb 100% of samples lower than AL	0 samples of 36 higher than 15 ppb (90 <sup>th</sup> percentile = 2.0 ppb)	Corrosion of household plumbing systems; Erosion of natural deposits
<b>Regulated in the Distribution System</b>				
Haloacetic Acids (HAA5)	N/A	60 ppb based on 4-quarter running annual average	22.5 ppb highest 4-quarter locational running annual average (5.7 -31.7)**average	By-product of chlorinating drinking water
Total Trihalomethanes	N/A	80 ppb based on 4-quarter running annual average	61.9 ppb highest 4-quarter locational running annual average (27.3 – 83.5)**	By-product of chlorinating drinking water
Chlorine	MRDLG = 4 ppm	MRDL = 4 ppm	0.37 ppm annual average (<0.01 – 0.98)	Water additive used to control microbes
Total Coliform	N/A	5% positive/month	0% positive in any month	Total coliforms are a group of non-harmful bacteria that are used as indicator organisms to determine the adequacy of water treatment
<b>Unregulated Contaminants (2019)</b>				
Unregulated contaminants are those that do not yet have a drinking water standard set by USEPA. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard.				
Haloacetic Acids (HAA6)	N/A	N/A	20.9 ppb (1.8 – 20.9)	By-product of chlorinating drinking water
Haloacetic Acids (HAA9)	N/A	N/A	0.26 ppb (0.23 – 0.26)	By-product of chlorinating drinking water
Manganese	N/A	N/A	0.062 ppb (<0.03 – 0.062)	Erosion of natural deposits
PFOA	N/A	*** 70 ppt	3 ppt	*** See below

\* Although there is no EPA MCL for Sodium, the State of CT requires that systems exceeding 28 ppm must notify their customers, so that individuals on a sodium restricted diet can inform their physician.

\*\* The range of individual results for Trihalomethanes and Haloacetic Acids

There is no State or EPA MCL for Sulfate, although the State of CT requires monitoring. Sulfate was detected in the range of 16.1 ppm to 23.3 ppm. The Hardness of your water ranged from 40 ppm to 60 ppm as CaCO<sub>3</sub>. A level exceeding 120 ppm is considered hard water. There is no MCL for Hardness.

\*\*\*EPA issued a Lifetime Health Advisory (LHA) for levels of two specific PFAS chemicals in drinking water— perfluorooctanoic acid (PFOA) and perfluorooctane sulfonic acid (PFOS)—of 70 ppt, either individually or combined. In December 2016, DPH issued an Action Level (AL) of 70 ppt for the combined levels of PFOA, PFOS, and three additional PFAS chemicals. This information was shared with the state's public water systems and local officials. Used in consumer products such as nonstick cookware, waterproof apparel, stain-resistant textiles and carpets, personal care products, cleaners, waxes, and food packaging materials. Industrial applications such as metal finishing operations and as the primary ingredient in firefighting foam used to extinguish high-hazard flammable liquid fires.

**Definitions:**

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Nephelometric Turbidity Unit (NTU):** A measure of the cloudiness of water. We monitor turbidity because it is a good indicator of the effectiveness of our filtration system.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**ppm:** Parts per million, or milligrams per liter (mg/L), **ppb:** Parts per billion, or micrograms per liter (µg/L), **ppt:** Parts per trillion

**For More Information:**

En Español: Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien.

The Board of the District Commissioners' regular meeting is held on the 3<sup>rd</sup> Tuesday of each month at 1 State Street in Norwalk, CT.

For more information about your drinking water or this report, call our Laboratory manager at 203-762-7884 ext. 4302, or the Connecticut Department of Public Health, Drinking Water Section at 860-509-7333.