

**2016
Lead Compliance Test Results**

<u>Rank</u>	<u>Collection Date</u>	<u>Lead Result (ppb)</u>
1	07/14/16	ND <1
2	07/14/16	ND <1
3	09/15/16	ND <1
4	07/13/16	ND <1
5	07/13/16	ND <1
6	07/14/16	ND <1
7	09/14/16	ND <1
8	07/14/16	ND <1
9	07/14/16	ND <1
10	07/14/16	ND <1
11	07/14/16	ND <1
12	07/13/16	1
13	08/02/16	1
14	08/25/16	1
15	07/14/16	1
16	07/14/16	1
17	07/14/16	1
18	09/15/16	1
19	07/14/16	1
20	07/29/16	1
21	07/13/16	2
22	09/14/16	2
23	07/28/16	2
24	07/14/16	2
25	07/14/16	2
26	07/14/16	2
27	07/13/16	2
28	07/13/16	4
29	07/13/16	4
30	07/14/16	6

SNEW was in compliance in 2016

AL = 15 ppb; 90% of samples should be lower than AL

100% of SNEW samples were lower than the AL

Action Level (AL): The concentration of a contaminant which if exceeded, triggers action to lower the level of the contaminant

ppb: Parts per billion

ND: None detected

**2019
Lead Compliance Test Results**

<u>Rank</u>	<u>Collection Date</u>	<u>Lead Result (ppb)</u>
1	06/11/19	ND <1
2	06/11/19	ND <1
3	06/11/19	ND <1
4	06/11/19	ND <1
5	06/11/19	ND <1
6	06/11/19	ND <1
7	06/11/19	ND <1
8	06/11/19	ND <1
9	06/11/19	ND <1
10	06/12/19	ND <1
11	06/11/19	ND <1
12	06/11/19	ND <1
13	06/11/19	ND <1
14	06/11/19	ND <1
15	06/11/19	ND <1
16	06/12/19	ND <1
17	06/12/19	ND <1
18	06/11/19	ND <1
19	06/11/19	ND <1
20	06/11/19	ND <1
21	06/11/19	ND <1
22	06/10/19	ND <1
23	06/19/19	ND <1
24	06/11/19	1
25	06/11/19	1
26	06/11/19	1
27	06/11/19	2
28	06/11/19	2
29	06/11/19	2
30	06/11/19	2
31	06/11/19	2
32	06/11/19	2
33	06/11/19	2
34	06/11/19	3
35	06/11/19	3
36	06/11/19	4

SNEW is currently compliance

AL = 15 ppb; 90% of samples should be lower than AL

100% of SNEW samples were lower than the AL

Action Level (AL): The concentration of a contaminant which if exceeded, triggers action to lower the level of the contaminant

ppb: Parts per billion

ND: None detected